



CAT III 500V

T1800 1000V

- Analogue Insulation Tester
- Heavy duty carry case
- Taut band movement
- Auto discharge
- Colour coded scale
- Live circuit indication
- AC Voltage measurement

Technical Overview

Feature	Parameter	Accuracy
Test Voltages (DC) and Measuring Range	250V (0 - 100M Ω), 500V (0 - 200M Ω), 1000V (0 - 400M Ω)	\pm 5% of Indicated value
Short Circuit Terminal Current	145mA DC Approx	
Output Voltage on Open Circuit	Rated test voltage + 10%	
Short Circuit Current (Max)	2mA DC	
Continuity Range	0 -50 Ω	
Open Circuit Terminal Voltage	445mV DC Approx	
Voltage Measurement	0 -500 V AC	2.5% of scale length

Model Specification

Power Source	8 x 1.5V AA Alkaline Batteries
Standard Accessories	Test Leads TAL24 (P55), Pouch, Shoulder strape
Certificates	UL, IEC61010-1. Certificate of Conformance

Johannesburg
Tel: (011) 879-6620

Cape Town
Tel: (021) 594-7100

Durban
Tel: (031) 492-0481

Port Elizabeth
Tel: (041) 408-2400

